Treadway, David

From: Treadway, David
Sent: Monday, October 19, 2020 9:23 AM
To: Deister, Beri; Malone, Keisha; Jones, Victor
Cc: Powell, Patricia
Subject: Limited Mold Assessment Rm 120

Dr. Deister,

Good Morning. My name is David Treadway and I am the Environmental Coordinator for the district. I am sending this email to follow up with the results of the limited mold assessment conducted in Room 120. Ensolum LLC conducted a limited mold assessment in Rm 120 on September 15th per a campus request. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools, average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 120 ,was **.05%** of the outdoor levels. Utilizing this theory, the indoor concentration levels were well within the acceptable guidelines for areas with filtered or air conditioned air. Please let me know if you or your team have any questions.

Sincerely,
David Treadway
LISD Environmental Coordinator

ENSOLUM

September 18, 2020

Lewisville Independent School District
340 Lake Haven
Lewisville, Texas 75057
Attn: Mr. David Treadway

Re:
Limited Mold Assessment
Lakeview Middle School
Room 120
4300 Keys Drive
The Colony, Texas
Ensolum Project No. 01A.1288.104

Ensolum, LLC (Ensolum) was retained to perform limited mold assessment services within room 120 of Lakeview Middle School located at 4300 Keys Drive in The Colony, Texas. Enclosed is the report, including analytical data.

Ensolum appreciates this opportunity to be of service and looks forward to our continued work together. Please contact the undersigned with any questions or concerns you may have.

Sincerely,

Clinton S. Jech
Mold Assessment Consultant
MAC1444 EXP: 10/09/2021

Darren G. Bowden
Principal
MAC0321 EXP: 2/14/2022

1.0 INTRODUCTION

Ensolum was retained by Mr. David Treadway, LISD, to complete a Limited Mold Assessment within room 120 of Lakeview Middle School located at 4300 Keys Drive in The Colony, Texas. The purpose of this investigation was to determine if elevated concentrations of airborne fungal spores and structures were present within the above-referenced areas.

Mr. Clinton S. Jech completed the on-site investigation on September 15, 2020. The Limited Mold Assessment was performed in response to a complaint of possible indoor air quality issues within specific areas.

2.0 PROCEDURE

Ensolum visually inspected accessible areas of room 303. Visible water damage was observed in the following locations:

VISIBLE WATER DAMAGE		
LOCATION	DATE	EXPLANATION
Room 120	9-15-2020	N/A

Following the inspection of potential water-damaged building materials, Ensolum conducted a moisture investigation in the identified areas to determine if nonvisible water-damaged materials and other building materials within the investigation area were present. The moisture investigation was completed with a GE Protimeter BLD5364 moisture meter on accessible porous and semi-porous building materials in each area of concern. At the time of investigation, monitored building materials did not exhibit elevated moisture concentrations in comparison with similar and non-affected building materials in the structure and standard scientific guidelines.

Representative Relative Humidity readings were collected and recorded using an Extech Instruments Humidity / Temperature Pen. Measurements recorded during the investigation are listed in the chart below:

TEMPERATURE, RELATIVE HUMIDITY & SPECIFIC HUMIDITY				
LOCATION	DATE	Temperature: F	Relative Humidity	Specific Humidity
Exterior, Southeast	9-15-2020	85	64	116
Exterior, Southwest	9-15-2020	93	46	107
Room 303	9-15-2020	74	39	48

Area air samples were collected with Zefon Air-O-Cell spore trap cassettes and analyzed for airborne fungal spores and structures. Samples were collected at a rate of 15 liters per minute. Indoor air sample(s) were collected for a five (5) minute period of time (75 liters) at a height of approximately five (5) feet above finished floor (AFF). Outdoor air samples were collected for a five (5) minutes period of time (75 liters) at a height of approximately five (5) feet above level ground. American Conference of Governmental Industrial Hygienists (ACGIH) guidelines were followed for the sample collection. Fungal air samples were collected in the following areas:

SPORE TRAP LOCATIONS	
SAMPLE NUMBER	LOCATION
1	Exterior, Southeast
2	Exterior, Southwest
3	Room 120

3.0 RESULTS

Currently, there are no regulatory standards for airborne fungal contamination. Therefore, results of the fungal analysis are compared against scientific guidelines. Bioaerosol samples are evaluated by comparing the indoor samples against the outdoor sample. The same types of fungi should be found in both the indoor and outdoor samples.

Should higher fungal concentrations occur in the indoor sample(s) or complaint areas, this generally indicates there is a source of fungal growth in the area. The types of fungi are also evaluated-the same types/genus of fungi should be present in both the indoor/complaint and outdoor/non-complaint samples.

The results of the fungal air samples collected were evaluated. Air testing performed using spore traps found that airborne mold spores in the room were considerably lower and were qualitatively similar to those measured outside of the building at the time the sampling was performed.

CONCLUSIONS

Based on ENSOLUM's limited assessment and the analytical results, it appears that the indoor air quality, as it relates to airborne fungi, was within recommended guidelines on this day.

APPENDIX A

ANALYTICAL DATA

IAQ Mold Report

Summary

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460
TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-20 - Standard Profile

Lab Job No. : 20F-09831
Report Date : 09/17/2020
Sample Date: 09/15/2020
Spore Trap Type: Zefon - Air-O-Cell

On 9/15/2020, three (3) samples were submitted by Clint Jech of Ensolum, LLC (located at 2351 W. Northwest Hwy Suite #1203, Dallas, TX 75220) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter	
1	75	Exterior, Southeast * See Analytical Notes report for further details	Basidiospores	6734	40%
			Cladosporium	3963	23%
			Agaricales group	1146	7%
			Aspergillus / Penicillium	946	6%
			Coprinus group	920	5%
			Ascospores	813	5%
			Cercospora / Pseudocercospora	560	3%
			Myxomycete / Periconia / Rust / Smut	507	3%
			Alternaria	360	2%
			Hyphal / Spore Fragments - Dematiaceous	293	2%
			Curvularia	187	1%
			Fusarium	173	1%
			Ganoderma	120	<1%
			Drechslera / Bipolaris / Helminthosporum / Exserohilum group	80	<1%
			Pithomyces	67	<1%
			Nigrospora	67	<1%
			Pyricularia	27	<1%
			Ulocladium / Stemphylium	13	<1%
			Pestalotia / Pestalotiopsis	13	<1%
			Torula	13	<1%
			Total:	17002	100%

IAQ Mold Report

Summary

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-20 - Standard Profile

Lab Job No. : 20F-09831
Report Date : 09/17/2020
Sample Date: 09/15/2020
Spore Trap Type: Zefon - Air-O-Cell

On 9/15/2020, three (3) samples were submitted by Clint Jech of Ensolum, LLC (located at 2351 W. Northwest Hwy Suite #1203, Dallas, TX 75220) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter	
2	75	Exterior, Southwest * See Analytical Notes report for further details	Cladosporium	11700	39%
			Basidiospores	7134	24%
			Curvularia	4254	14%
			Hyphal / Spore Fragments - Dematiaceous	1306	4%
			Agaricales group	1066	4%
			Ascospores	973	3%
			Coprinus group	826	3%
			Cercospora / Pseudocercospora	560	2%
			Drechslera / Bipolaris / Helminthosporum / Exserohilum group	507	2%
			Myxomycete / Periconia / Rust / Smut	400	1%
			Aspergillus / Penicillium	400	1%
			Paecilomyces	347	1%
			Alternaria	200	<1%
			Fusarium	200	<1%
			Acremonium-like	147	<1%
			Nigrospora	133	<1%
			Pithomyces	40	<1%
			Ganoderma	40	<1%
			Torula	13	<1%
			Total:	30246	100%

IAQ Mold Report

Summary

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-20 - Standard Profile

Lab Job No. : 20F-09831
Report Date : 09/17/2020
Sample Date: 09/15/2020
Spore Trap Type: Zefon - Air-O-Cell

On 9/15/2020, three (3) samples were submitted by Clint Jech of Ensolum, LLC (located at 2351 W. Northwest Hwy Suite #1203, Dallas, TX 75220) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter	
3	75	Room 120	Basidiospores	53	31%
			Aspergillus / Penicillium	53	31%
			Hyphal / Spore Fragments - Dematiaceous	27	16%
			Drechslera / Bipolaris / Helminthosporum / Exserohilum group	13	8%
			Curvularia	13	8%
			Ascospores	13	8%
			Total:	172	100%

Analyst(s): Anshu Singh

Lab Director : Heather Lopez — Approved Signatory : Heather Lopez

Lab Director : Bruce Crabb — Approved Signatory : Bruce Crabb

Thank you for choosing Moody Labs

This Page Left Intentionally Blank

IAQ Mold Report

Data Detail

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460
TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-20 - Standard Profile

Lab Job No. : 20F-09831
Report Date : 09/17/2020
Sample Date: 09/15/2020
Spore Trap Type: Zefon - Air-O-Cell

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Sample ID:	1					2					3				
Location:	Exterior, Southeast					Exterior, Southwest					Room 120				
Media Expires On:	Mar 2021					Mar 2021					Mar 2021				
Notes Included:	See Analytical Notes					See Analytical Notes									
Volume:	75					75					75				
	raw ct	RL	spores/m³	%total	spores/m³ SF	raw ct	RL	spores/m³	%total	spores/m³ SF	raw ct	RL	spores/m³	%total	spores/m³ SF
Acremonium-like						11	13	147	<1%	150					
Agaricales group	86	13	1146	7%	1100	80	13	1066	4%	1100					
Alternaria	27	13	360	2%	360	15	13	200	<1%	200					
Ascospores	61	13	813	5%	810	73	13	973	3%	970	1	13	13	8%	10
Aspergillus / Penicillium	71	13	946	6%	950	30	13	400	1%	400	4	13	53	31%	50
Basidiospores	101	67	6734	40%	6700	107	67	7134	24%	7100	4	13	53	31%	50
Cercospora / Pseudocercospora	42	13	560	3%	560	42	13	560	2%	560					
Chaetomium															
Cladosporium	109	36	3963	23%	4000	117	100	11700	39%	12000					
Coprinus group	69	13	920	5%	920	62	13	826	3%	830					
Curvularia	14	13	187	1%	190	117	36	4254	14%	4300	1	13	13	8%	10
Drechslera / Bipolaris / Helminthosp	6	13	80	<1%	80	38	13	507	2%	510	1	13	13	8%	10
Fusarium	13	13	173	1%	170	15	13	200	<1%	200					
Ganoderma	9	13	120	<1%	120	3	13	40	<1%	40					
Hyphal / Spore Fragments - Dematia	22	13	293	2%	290	98	13	1306	4%	1300	2	13	27	16%	30
Hyphal / Spore Fragments - Hyaline															
Myxomycete / Periconia / Rust / Sm	38	13	507	3%	510	30	13	400	1%	400					
Nigrospora	5	13	67	<1%	70	10	13	133	<1%	130					
Paecilomyces						26	13	347	1%	350					
Pestalotia / Pestalotiopsis	1	13	13	<1%	10										
Pithomyces	5	13	67	<1%	70	3	13	40	<1%	40					
Pyricularia	2	13	27	<1%	30										
Stachybotrys															
Torula	1	13	13	<1%	10	1	13	13	<1%	10					
Ulocladium / Stemphylium	1	13	13	<1%	10										
TOTALS	683		17002	100%	17000	878		30246	100%	30000	13		172	100%	170
Analyst	Anshu Singh					Anshu Singh					Anshu Singh				
Analysis Date	9/16/2020					9/16/2020					9/16/2020				
Debris Rating	5					5					1				
Debris Composition															
Fibers	1/5					1/5					1/5				
Inorganic/Other	2/5					2/5					1/5				
Insect Parts	0/5					0/5					0/5				
Pollen	5/5					5/5					0/5				
Skin/Dander	1/5					1/5					1/5				

IAQ Mold Report

Data Detail

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-20 - Standard Profile

Lab Job No. : 20F-09831
Report Date : 09/17/2020
Sample Date: 09/15/2020
Spore Trap Type: Zefon - Air-O-Cell

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

End of Data Detail section
20F-09831

This Page Left Intentionally Blank

IAQ Mold Report

Analytical Notes

2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-20 - Standard Profile

Lab Job No. : 20F-09831
Report Date : 09/17/2020
Sample Date : 09/15/2020
Spore Trap Type: Zefon - Air-O-Cell

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Samples Analyzed

Sample No	1 : Exterior, Southeast
Notes:	5% Occluded. Please note: the minimum reporting limit for Basidiospores is 67 spores / cubic meter. When comparing results to other samples, use calculated results, not raw numbers. Please note: the minimum reporting limit for Cladosporium is 36 spores / cubic meter. When comparing results to other samples, use calculated results, not raw numbers.
Sample No	2 : Exterior, Southwest
Notes:	5% Occluded. Please note: the minimum reporting limit for Cladosporium is 100 spores / cubic meter. When comparing results to other samples, use calculated results, not raw numbers. Please note: the minimum reporting limit for Basidiospores is 67 spores / cubic meter. When comparing results to other samples, use calculated results, not raw numbers. Please note: the minimum reporting limit for Curvularia is 36 spores / cubic meter. When comparing results to other samples, use calculated results, not raw numbers.

Field Blanks

No discernable field blanks were submitted with this set of samples.

NOTE: All remaining samples suitable for analysis.

IAQ Mold Report

Analytical Notes

2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-20 - Standard Profile

Lab Job No. : 20F-09831
Report Date : 09/17/2020
Sample Date : 09/15/2020
Spore Trap Type: Zefon - Air-O-Cell

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Methods

Method: ASTM D7391-20: Categorization and Quantification of Airborne Fungal Structures in an Inertial Impaction Sample by Optical Microscopy.
Samples are read at 100% unless noted. Partial readings may be employed when concentrations are elevated. Use final spore concentrations, not raw spore counts, for interpretation of results.

Calculation: Spores/cubic meter = (Raw spore count)*(RL)
Note: RL (Reporting Limit) is based upon 1 raw spore count.
Moody Labs recommends two significant figures for calculated values based on ASTM D7391-20.

This report must not be used by the customer to claim product certification, approval, or endorsement by AIHA, ISO, or any agency of the Federal Government.

Debris Rating Key

0 - No linear trace detected
1 - Trace particulate/debris
2 - Light particulate/debris
3 - Moderate particulate/debris
4 - Substantial particulate/debris
5 - Extensive particulate/debris
6 - Field blank
10 - Hold Sample
11 - Modified Analysis per Client Instructions

NOTE: Particulate/debris are defined as skin, fibers, pollen grains, insect parts, fungal and/or other non-fungal particles.

IAQ Mold Report

Analytical Notes

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460
TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-20 - Standard Profile

Lab Job No. : 20F-09831
Report Date : 09/17/2020
Sample Date : 09/15/2020
Spore Trap Type: Zefon - Air-O-Cell

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Lab ID # 102577

End of Analytical Notes section
20F-09831

This Page Left Intentionally Blank

IAQ Mold Report

Supplemental Overview

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104

Lab Job No. 20F-09831
Report Date 09/17/2020
Sample Date : 09/15/2020



Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

IAQ Mold Report

Supplemental Overview

TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104

Exterior, Southeast

Lab Job No. 20F-09831
Report Date 09/17/2020
Sample Date : 09/15/2020



Average Reference 1 = Exterior, Southeast

Average Reference 2 = Exterior, Southwest

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

IAQ Mold Report

Supplemental Overview

TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104

Exterior, Southwest

Lab Job No. 20F-09831
Report Date 09/17/2020
Sample Date : 09/15/2020



Average Reference 1 = Exterior, Southeast

Average Reference 2 = Exterior, Southwest

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

IAQ Mold Report

Supplemental Overview

TDLR License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Ensolum, LLC
Project : Lakeview MS Room 120
Project # : 01A.1288.104

Room 120

Lab Job No. 20F-09831
Report Date 09/17/2020
Sample Date : 09/15/2020



Average Reference 1 = Exterior, Southeast

Average Reference 2 = Exterior, Southwest

End of Supplemental Overview section
20F-09831

APPENDIX B

DEFINITIONS AND LIMITATIONS

ENSOLUM

Mold Services Definitions & Limitations

Ensolum performed services in accordance with generally accepted practices of the profession undertaken in similar services at the same time and in the same geographical area. No other warranties, express or implied, apply to the services hereunder or the final report.

Ensolum's services and any report have been prepared on behalf of and for the exclusive use of the Client solely for its use and reliance in assessing the presence of mold in the Investigation Areas of the site. The Client was the only party to which Ensolum explained the risks and limitations of the services and was solely involved in shaping the scope of services. Accordingly, reliance on this report by any other party may involve assumptions leading to an unintended interpretation of findings and opinions. With the consent of the Client, Ensolum may offer reliance to third parties or contract with other parties to develop findings and opinions related to such party's unique risk management concerns. Notwithstanding the foregoing, reliance by any and all third parties upon this deliverable, Ensolum's services or any subsequent report shall be limited in the aggregate to the fair market value of the services provided by Ensolum.

"Limited Mold Assessment". This deliverable uses the term "Limited Mold Assessment" to denote that Ensolum's mold assessment services are limited: (i) to certain portions of the building structure (e.g., the Investigation Areas), by non-destructive sampling methodologies, and/or by access limitations to building materials or components within the Investigation Area(s). In contrast to a "Limited Assessment" is a comprehensive assessment would involve destructive sampling methods with the assessment to be conducted throughout the entire building structure.

Time sensitive. One must keep in mind that mold assessments are essentially a "snap shot in time," and the results are only relevant at the time of site reconnaissance. Because mold, when biologically active, is a living organism, its presence is influenced and controlled by environmental conditions. Mold assessments, therefore, are "time sensitive" in that the presence and concentration of mold and similar organisms in building structures or in the air is directly influenced by environmental conditions (such as humidity, moisture, nutrients and substrates), whether natural or caused by man, which conditions may vary significantly over relatively short periods of time.

Methodologies. Currently, mold assessment methodologies and protocols in Texas are governed by persuasive guidelines (rather than promulgated federal/state or local regulations). Presently, there is no data that supports a threshold limit or dose-response relationship for exposure to mold aeroallergens, individual pathogens, opportunistic pathogens and/or mycotoxins. The Occupational Safety and Health Administration (OSHA), the National Institute of Occupational Safety and Health (NIOSH) and other non-governmental associations, have not yet established permissible exposure limits (PELs), recommended exposure limits (RELs), or other limit values for fungi. Because no limit values presently exist. Ensolum will not and cannot represent that the site contains no harmful microbes, mold, fungi, or their metabolites, or other latent conditions beyond those identified by the limited scope of this mold assessment.

Findings limited. Findings in an LMA are limited due to the nature of the information obtained such as a visual reconnaissance of readily accessible areas of building structures, interview information, anecdotal information, and limited sampling data derived from one or more specific sampling events. Ensolum cannot warrant the accuracy of prior or subsequent information/data, reports and services performed by other firms at the Site. Ensolum assumes no responsibility or liability for errors in information or data provided by or through the client or third party sources. Ensolum's services are not to be construed as legal or medical interpretation or advice.

Moisture Intrusion Limitation. Ensolum performs mold assessment services and is not a moisture intrusion, HVAC, plumbing or building envelope specialist. However, during the course of conducting its mold assessment services, Ensolum will report observed areas of apparent moisture intrusion. Ensolum does not and will not investigate the cause or causes of such observed moisture intrusion. In the event apparent moisture intrusion is observed, Ensolum will recommend that the client contact a specialist (i.e., plumbing contractor, building envelope specialist, HVAC contractor, water intrusion specialist, etc.) to assist the client in determining the specific cause or causes of the moisture intrusion and remedial options.

Certificate of Mold Damage Remediation (CMDR). For mold remediation projects (above certain size thresholds), applicable Texas law (i.e., Texas Occupation Code Section 1958.54 and T.A.C. Section 295.397 (the Texas Mold Assessment and Remediation Rules), requires that a "Certificate of Mold Damage Remediation" be issued by the Mold Remediation Contractor upon successful completion of the project. This certificate must be provided to property owners no later than the 10th day after the date on which the mold remediation is completed at a property. The Mold Remediation Certificate issued by the Mold Remediation Contractor must include a certification by the Mold Assessor that the mold remediation project has been successfully completed in accordance with the mold remediation protocol.

Be advised that Ensolum's issuance of a CMDR upon successful completion of a Mold Remediation project does not mean, warrant or otherwise guarantee that mold will not be subsequently found in any portion of an Investigation Area or the Site. In the event that Ensolum is engaged to render services in connection with a mold remediation project, ENSOLUM will require Client to provide to Ensolum written documentation that all sources of moisture which contributed to the presence of mold in the Investigation Area have been fully remediated and corrected prior to achieving clearance.